

MFPA Leipzig GmbH

Testing, Inspection and Certification Authority for Construction Products and Construction Types

Center for Innovation and Calculation

Dr.-Ing. Susanne Reichel

Work Group - FEM

Dr.-Ing. Susanne Reichel Telefon +49 (0) 341-6582-106 s.reichel@mfpa-leipzig.de

Advisory Opinion No. GS6.1/19-009-2

05.04.2019

Object:

Assessment of the load bearing behaviour of bonded anchors HAS-D with injection system Hilti HIT-HY 200 under tensile loading and one-sided fire loading according to the standard-time-temperature-curve - steel failure, abbreviated version

Client: Hilti Aktiengesellschaft Feldkircherstraße 100 9494 Schaan Fürstentum Liechtenstein

Prepared by: Dr.-Ing. Susanne Reichel

This document covers 8 pages, including 0 appendices.

This document may only be reproduced in its unabbreviated form. All publication, even in excerpts, requires the prior written permission of MFPA Leipzig GmbH. The legal binding form is the written German form with the original signatures and original stamp of the authorized signatory / signatories. General terms and conditions of MFPA Leipzig GmbH are valid.

Gesellschaft für Materialforschung und Prüfungsanstalt für das Bauwesen Leipzig mbH (MFPA Leipzig GmbH)

Head Office: Managing Director: Comm. Register: VAT-ID: Tel.: Fax: Hans-Weigel-Str. 2b – 04319 Leipzig/Germany Dr.-Ing. habil. Jörg Schmidt Local Court Leipzig HRB 17719 DE 813200649 +49 (0) 341-6582-0 +49 (0) 341-6582-135

Verfasser:	MFPA Leipzig GmbH - Center for Innovation Hans-Weigel-Str 2b • 04319 Leipzig, Germany		MFPA
Programm:		ProjNr.: GS6.1/19-00)9-2
Bauwerk:	Advisory Opinion	ASB-Nr.:	Date: 05.04.2019
	Contents		
	I Objective and request	3	

2.2 Assessment and test reports

4

5 5

5

5

5

6

6

7

Ш

ш

IV

V

References

Special notes

Description of the construction

Assessment of the performance

Bauteil:	Table of contents			Archiv-Nr.:
Block:		Page:	2	
Vorgang:				

Verfasser:	MFPA Leipzig GmbH - Center for Innovation and Calculation Hans-Weigel-Str 2b • 04319 Leipzig, Germany • +49 (0) 341-6582-106			MFPA
Programm:		ProjNr.:	GS6.1/19-009)-2
Bauwerk:	Advisory Opinion	ASB-Nr.:		Date: 05.04.2019

I Objective and request

MFPA Leipzig GmbH was ordered by Hilti AG to assess the load bearing behaviour of bonded anchors HAS-D with injection system Hilti HIT-HY 200 under tensile loading and one-sided fire loading according to the standardtime-temperature-curve (STTC) according to [N1]. The assessment bases on results of fire tests for the failure mode "steel failure". The document at hand summarizes the characteristic tensile load bearing

The document at hand summarizes the characteristic tensile load bearing capacities. For details, please see [G1].

Bauteil:	I Objective and request			Archiv-Nr.:
Block:		Page:	3	
Vorgang:				

Verfasser:	MFPA Leipzig GmbH - Center for Innovation and Calculation Hans-Weigel-Str 2b • 04319 Leipzig, Germany • +49 (0) 341-6582-106			МГРА
Programm:		ProjNr.:	GS6.1/19-009	9-2
Bauwerk:	Advisory Opinion	ASB-Nr.:		Date: 05.04.2019

II Description of the construction

The injection system Hilti HIT-HY 200 is a bonded anchor for use in concrete constructions, consisting of a mortar cartridge, an anchor rod with cones as well as a hexagon nut and a washer. Figure 1 shows a principle picture of the anchor geometry.




Figure 1: Injection system Hilti HIT-HY 200 with anchor rod HAS-D: On-site geometry

Load transmission mainly occurs due to the mechanical toothing of the cones within the injection mortar as well as, in addition, a combination of cohesion and friction forces in the anchorage. The bonded anchors are approved for the use under static, quasi-static and fatigue loading in reinforced and unreinforced normal concrete of the strength class of at least C20/25 and at most C50/60 according to [N2]. The required diameter and depth of the drill hole as well as the minimum component thickness are specified for each anchor in [P1, P2]. In the course of installation of the bonded anchors, the manufacturers' instructions have to be obeyed (see [P1, P2]).

According to [P1, P2], the anchor rods are produced using galvanized steel according to [N3]. For a detailled product description and further information with respect to the scope of application, please see [P1, P2].

Bauteil:	11	Description of the construction			Archiv-Nr.:
Block:			Page:	4	
Vorgang:					

Verfasser:		A Leipzig GmbH - Center for In Weigel-Str 2b ● 04319 Leipzig, G	novation and Calculation ermany • +49 (0) 341-6582-106	MFPA		
Programm:	ProjNr.: GS6.1/19-009-2					
Bauwerk:	Adviso	ry Opinion	ASB-Nr.:	Date: 05.04.2019		
	ш	References				
	1 U	Itilized guidelines, rules ar	nd standards			
	The a	nalyses are based on the follow	wing guidelines, rules and standards	5.		
	[N1]	DIN EN 1363-1:2012-10: F Requirements; German versi	ire resistance tests - Part 1: Gene on EN 1363-1:2012	eral		
	[N2]		rete - Specification, performance, p man version EN 206:2013+A1:201			
	[N3]		ree-cutting steels - Technical delive products, hot-rolled bars and ro 998	5		
	[N4]	TR 020: Evaluation of Anch tance to Fire; 05/2004	norages in Concrete concerning Res	sis-		
	[N5]	EAD 330232-00-0601: Mec 10/2016	hanical fasteners for use in concre	te;		
	[N6]		Eurocode 2: Design of concrete stru ules - Structural fire design; Germ - AC:2008			
	2 R	eference documents				
	The a	nalyses are based on the follow	wing additional documents:			
	2.1	Verifications of applicability				
	[P1]	ETA-18/0972: Hilti Injekti nach EAD 330499	onssystem HIT-HY 200 mit HAS	-D		
	[P2]	ETA-18/0978: Hilti Injekti nach EAD 330250	onssystem HIT-HY 200 mit HAS	-D		
	2.2	Assessment and test reports	5			
	[G1]		1/19-009-1: Assessment of the lo anchors HAS-D with injection syste			

[G1] Advisory Opinion No. GS6.1/19-009-1: Assessment of the load bearing behaviour of bonded anchors HAS-D with injection system Hilti HIT-HY 200 under tensile loading and one-sided fire loading according to the standard-time-temperature-curve - steel failure – MFPA Leipzig GmbH; 04.04.2019

Bauteil: III References

Block: 2 Reference documents

Page: 5

Archiv-Nr.:

Vorgang: 2.2 Assessment and test reports

Verfasser:	MFPA Leipzig GmbH - Center for Innovation and Calculation Hans-Weigel-Str 2b • 04319 Leipzig, Germany • +49 (0) 341-6582-106			MFPA
Programm:		ProjNr.:	GS6.1/19-009)-2
Bauwerk:	Advisory Opinion	ASB-Nr.:		Date: 05.04.2019

IV Assessment of the performance

1 Steel failure

Basing on experimental results and respective evaluations (see [G1]), Table 1 shows the characteristic tensile load bearing capacities $N_{Rk,s,fi}(t)$ for steel failure.

	fire duration [min]			
	30	60	90	120
HAS-D 100 M12	5.80	3.80	1.81	0.81
HAS-D 125 M16	7.62	5.81	4.01	3.11
HAS-D 170 M20	13.02	9.75	6.48	4.84

Table 1: Injection system Hilti HIT-HY 200 with anchor rod HAS-D (galvanized steel): Characteristic tensile load bearing capacity $N_{Rk,s,fi}(t)$ [kN] for steel failure

Bauteil:	IV Assessment of the performance			Archiv-Nr.:
Block:	1 Steel failure	Page:	6	
Vorgang:				

Verfasser:	MFPA Leipzig GmbH - Center for Innovation and Calculation Hans-Weigel-Str 2b • 04319 Leipzig, Germany • +49 (0) 341-6582-106			MFPA
Programm:		ProjNr.:	GS6.1/19-009-2	2
Bauwerk:	Advisory Opinion	ASB-Nr.:		Date: 05.04.2019

V Special notes

The assessment at hand is valid for bonded anchors HAS-D with injection system Hilti HIT-HY 200 manufactured by Hilti AG which are installed according to the manufacturers' instructions in [P1, P2]. The mechanical loading may not exceed the load bearing capacity in ambient climate specified in [P1, P2].

The load bearing capacities specified in the framework of the document at hand are determined for one-sided fire loading according to the standard-time-temperature-curve. According to [N4], the values may also be used for multilateral fire loading when the edge distance of the anchor is $c \geq 300 mm$ and $c \geq 2 \cdot h_{ef}$.

The load bearing capacities specified in the framework of the document at hand are determined for centrical tensile loading in the anchors longitudinal direction. According to [N5], the values may be transferred to tensile loading perpendicular and diagonal to the axis of the anchor on the safe side.

The assessment at hand is valid for constructions of reinforced or unreinforced normal concrete of the stength class \geq C20/25 and \leq C50/60 according to [N2], which exhibit at least the same fire resistance class as the utilized anchors. The design of the concrete construction has to be carried out according to [N6].

The load bearing capacities specified in the framework of the document at hand are determined assuming that no explosive concrete spalling occurs and are only valid under this condition. Evidence on the prevention of explosive concrete spalling is given in [N6], chapter 4.5.

Bauteil:	V	Special notes			Archiv-Nr.:
Block:			Page:	7	
Vorgang:					

Verfasser:	MFPA Leipzig GmbH - Center for Innovation and Calculation Hans-Weigel-Str 2b • 04319 Leipzig, Germany • +49 (0) 341-6582-106			
Programm		ProjNr.:	GS6.1/19-009	-2
Bauwerk:	Advisory Opinion	ASB-Nr.:		Date: 05.04.2019
	This document does not replace a certif according to national and European build		r suitability	
	Leipzig, 05.04.2019			
	S. Michel DrIng. S. Reichel			9
	Head of Business Division			
				1.82
				108 C
Bauteil:	V Special notes			Archiv-Nr.:
Block:		Page:	8	
Vorgang:				