

Pipe Hangers

Pipe hangers are used to support a sprinkler piping system from the building structure. Two or more listed components may be required to form a complete hanger. The specific components required depend upon the type of building construction and the pipe size.

Pipe Hangers

Product Designation	Hanger Rod Size, in. NC	Component Description	For Nominal Pipe Size, in.
MP-MX 125	M16	Pipe Ring Clamp	125 mm
MP-MX 133	M16	Pipe Ring Clamp	133 mm
MP-MX 5"	M16	Pipe Ring Clamp	5 in.
MP-MX 159	M16	Pipe Ring Clamp	159 mm
MP-MX 6"	M16	Pipe Ring Clamp	6 in.

Product Designation	Hanger Rod Size, mm	Component Description	Nominal Pipe Sizes, mm	
MAB-M10	10	Beam Clamp	20 through 100 mm	
MAB-10	10	Beam Clamp	20 through 100 mm	
MAB-M12	12	Beam Clamp	20 through 200 mm	
MAB-13	12	Beam Clamp	20 through 200 mm	
MAB-M16	16	Beam Clamp	20 through 300 mm	
MAB-17	16	Beam Clamp	20 through 300 mm *	
MQT-G M10	10	Swivel Beam Clamp	20 through 100 mm	
* Approved for use with the set so	rew on the load side			

Product Designation	Hanger Rod Size, inch (metric)	Component Description	For Nominal Pipe Size, in.
LH	3/8 (M10)		3/4 through 4



LH	1/2 (M12)	Loop Hanger	6 and 8
SDC EG	1/2 (M12)	Clevis Hanger	2-1/2 and 3
SDC EG	5/8 (M16)	Clevis Hanger	4 and 5
SDC EG	3/4 (M20)	Clevis Hanger	6 and 8

Product Designation	Hanger Rod Size, in. (mm)	Component Description	For Nominal Pipe Size, in.
SLC-EG	3/8 (M10)	Clevis Hanger	2 and 2-1/2
SLC-EG	1/2 (M12)	"	3
SLC-EG	5/8 (M16)	"	4 and 5
SLC-EG	3/4 (M20)	"	6 and 8

Company Name:	Hilti AG		
Company Address:	ss: Feldkircherstrasse 100, Box 333 , 9494 Schaan , Liechtenstein		
Company Website:	http://www.hilti.com		
Listing Country:	Liechtenstein		
Certification Type:	FM Approved		