

Attestation

EMICODE

On the 19th of January 2024, Eurofins Product Testing A/S received a sample of a spray adhesive with the product name:

Ampacoll Airmax

supplied by

Ampack AG

The emission of organic compounds from the sample were measured in accordance with the test method as defined by GEV in its version by September 2022. (See report No.392-2024-00029701_G_EN).

Evaluation of the test result according to EC 1 PLUS for Installation Products, Adhesives and Building Materials:

- Carcinogenic substances were not detectable after 3 and after 28 days.
 - The TVOC after 3 days was below the limit of 750 µg/m³.
 - The TVOC after 28 days was below the limit of 60 µg/m³.
 - The TSVOC after 28 days was below the limit of 40 µg/m³.
 - After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m³. This value R was below the limit of 1.
 - The sum of VOC without LCI-value after 28 days was below the limit of 40 µg/m³.
 - After 3 days the concentration of both formaldehyde and acetaldehyde were below the limit of 50 µg/m³.
 - The sum of formaldehyde and acetaldehyde after 3 days was below the limit of 0.05 ppm.
-

This certificate does not alone entitle to use the protected trademark label EMICODE. For the use of an EMICODE label, a license has to be applied for at the GEV, Düsseldorf, Germany.

4 March 2024



Mads Folkjær
Analytical Chemist



Rasmus Verdier
Analytical Service Manager